

TABLE 2-5

**TOWN-WIDE WASTEWATER FLOW ESTIMATES
(NOT INCLUDING INFILTRATION AND INFLOW)**

CONDITION	FLOW (MGD)
Existing (2003) Average Annual Flow ⁽¹⁾	1.0
Build-out (BO) Average Annual Flow	1.3
Build-out Summer Average Flow	2.1
Build-out Minimum Month Flow	0.86
Build-out Maximum Month Flow	2.5
Build-out Peak Day Flow	2.9
Build-out Peak Hourly Flow	4.5
Note: 1. Calculated flow based on 2002-2003 water data and existing Town-wide land use and units based on 2004 Town assessors data.	

TABLE 2-6

INFILTRATION AND INFLOW ESTIMATE

CONDITION	FLOW (GPD)
Existing Collection System	20,000
Preliminary Gravity Sewer Layout	350,000
Laterals (All Phases)	160,000
Total	530,000