

TABLE 2-2

**SUMMARY OF WASTEWATER NITROGEN
REMOVAL NEEDS TO MEET NITROGEN TMDLS**

EMBAYMENT SYSTEM	EMBAYMENT	PERCENT REMOVAL WASTEWATER NITROGEN TO MEET MEP LIMIT ⁽¹⁾
Stage Harbor System	Oyster Pond	100
	Oyster River	100
	Stage Harbor	100
	Little Mill Pond	50
	Mill Pond	50
	Mitchell River	50
Sulphur Springs System	Bucks Creek	0
	Cockle Cove Creek	0
	Sulphur Springs	62.2
Taylors Pond System	Mill Creek	100
	Taylors Pond	40
Bassing Harbor System	Crows Pond	0
	Ryder's Cove	75
	Bassing Harbor	0
	Frost Fish Creek	100
Muddy Creek System	Muddy Creek Lower	100
	Muddy Creek Upper	75
Note: 1. Based on the findings of the 2006 MEP Reports for Pleasant Bay and the update to the 2003 MEP report for Stage Harbor, Sulphur Springs, Taylors Pond, Bassing Harbor, and Muddy Creek.		